



Bureau de normalisation
du Québec

BNQ is a member of the National
Standards System (NSS).

ANNEX TO THE CERTIFICATE

TECHNOLOGIES BIONEST INC.

Page 1 of 5

(BIONEST TECHNOLOGIES INC.)

55, 12e Rue
Shawinigan, Québec G9T 5K7

NQ 3680-910/2000-06-16 M1 (2004-09-10)

*Wastewater Treatment - Stand-Alone Wastewater Treatment
Systems for Isolated Dwellings*

Certificate number: **900**

Issue date: **2025-10-07**

Expiry date: **2027-10-31**

Stand-alone wastewater treatment systems

Bionest Model

Treatment chain Primary treatment and Bionest reactor

Capacity :

Number of bedrooms	Total daily total flow (L/d)	Model Designation	Hydraulic capacity (l/d)	Primary treatment (m ³)	Bionest Reactor (m ³)
1	0-540	SA-3	1260	3.4	3.4
2	541-1080	SA-3	1260	3.4	3.4
3	1081-1260	SA-3	1260	3.4	3.4
4	1261-1440	SA-4	1440	3.9	3.9
5	1441-1800	SA-5	1800	4.3	4.3
6	1801-2160	SA-6	2160	4.8	4.8
6	2161-2700	SA-6C27	2700	5.7	5.7
6	2701-3240	SA-6C32	3240	6.8	6.8

Material : Concrete or plastic

Certificate details

Treatment class : Class III.

Influent wastewater
Temperature: The tests specified in sections 8.1 and 8.2 were carried out with influent wastewater at a minimal
controlled temperature of 18°C.

Other : This treatment chain includes a primary reactor (septic tank with recirculation) as primary treatment.



**Bureau de normalisation
du Québec**

BNQ is a member of the National
Standards System (NSS).

ANNEX TO THE CERTIFICATE

TECHNOLOGIES BIONEST INC.
(BIONEST TECHNOLOGIES INC.)

55, 12e Rue
Shawinigan, Québec G9T 5K7

NQ 3680-910/2000-06-16 M1 (2004-09-10)

*Wastewater Treatment - Stand-Alone Wastewater Treatment
Systems for Isolated Dwellings*

Page 2 of 5

Certificate number: **900**
Issue date: **2025-10-07**
Expiry date: **2027-10-31**

Bionest model with UV disinfection

Treatment chain Primary reactor and Bionest reactor with UV reactor

Capacity :

Number of bedrooms	Total daily total flow (L/d)	Model Designation	Maximum hydraulic capacity (l/d)	Primary treatment (m³)	Bionest Reactor (m³)
1	0-540	SA-3D	1260	3.4	3.4
2	541-1080	SA-3D	1260	3.4	3.4
3	1081-1260	SA-3D	1260	3.4	3.4
4	1261-1440	SA-4D	1440	3.9	3.9
5	1441-1800	SA-5D	1800	4.3	4.3
6	1801-2160	SA-6D	2160	4.8	4.8
6	2161-2700	SA-6C27D	2700	5.7	5.7
6	2701-3240	SA-6C32D	3240	6.8	6.8

Material : Concrete or plastic

Authorized UV Reactors

Designation : UVMax « D » lamp model from TROJAN TECHNOLOGIES, is permitted up to a maximum of 3 240 l/d or a maximum disinfection rate of 2.8 L / min.
UV Sterilight Cobalt sc320 from Viqua is permitted up to a maximum of 3 240 l/d.

Certificate details

Treatment class : Class V.
Influent wastewater Temperature: The tests specified in sections 8.1 and 8.2 were carried out with influent wastewater at a minimal controlled temperature of 18°C.
Other : This treatment chain includes a primary reactor (septic tank with recirculation) as primary treatment.



**Bureau de normalisation
du Québec**

BNQ is a member of the National
Standards System (NSS).

ANNEX TO THE CERTIFICATE

TECHNOLOGIES BIONEST INC. (BIONEST TECHNOLOGIES INC.)

Page 3 of 5

55, 12e Rue
Shawinigan, Québec G9T 5K7

NQ 3680-910/2000-06-16 M1 (2004-09-10)

*Wastewater Treatment - Stand-Alone Wastewater Treatment
Systems for Isolated Dwellings*

Certificate number: **900**

Issue date: **2025-10-07**

Expiry date: **2027-10-31**

List of recognized manufacturers and assemblers for system components

Concrete manufacturers and assemblers:

Aubert & Marois ltée
842, rue Principale
Saint-Étienne, Québec G6J 1A8

Blocs Normand inc.
560, rue du Domaine
Ste-Agathe-des-Monts, Québec J8C 2Z4

Industries de Ciment La Guadeloupe inc.
238, 14^e Avenue
La Guadeloupe, Québec G0M 1G0

Béton Bolduc inc.
1358, 2^e Rue, Parc Industriel
Sainte-Marie, Québec G6E 1G8

Boisclair et fils inc.
715, boul. des Laurentides
Piedmont, Québec J0R 1K0

Rénova Béton Inc.
317, St-François-Xavier
Delson, Québec J5B 1X8

Béton Brunet 2001 inc.
300, avenue du Moulin
Mont-Laurier, Québec J9L 3E7

Ciment Lacasse ltée
48, montée Laramée
Sainte-Anne-des-Plaines, Québec J0N 1H0

Matériaux économiques inc.
2900, rue Jules-Vachon
Trois-Rivières, Québec G9A 5E1

Béton Provincial ltée, usine de Matane
1825, avenue du Phare Ouest
C. P. 160
Matane, Québec G4W 3M6

Groupe BPA inc.
71, avenue d'Auteuil
Saint-Basile, Québec G0A 3G0

Béton Provincial ltée
34, route 132 Ouest
Trois-Pistoles, Québec G0L 4K0

Béton Aquamix
8, rue d'Amours
Eastman, Québec J0E 1P0

Plastic assemblers :

Blocs Normand inc.
560, rue du Domaine
Ste-Agathe-des-Monts, Québec J8C 2Z4

Ciment Lacasse ltée
48, montée Laramée
Ste-Anne-des-Plaines, Québec J0N 1H0

Matériaux économiques inc.
2900, rue Jules-Vachon
Trois-Rivières, Québec G9A 5E1

Quincaillerie Touraine
1959, rue Saint-Louis
Gatineau, Québec J8T 4H6

Rénova Béton Inc.
317, rue St-François Xavier
Delson, Québec J5B 1X8

Boisclair & Fils inc.
715, boul. des Laurentides
Piedmont, Québec J0R 1K0

Aubert & Marois ltée
842, rue Principale
Saint-Étienne, Québec G6J 1A8



Bureau de normalisation
du Québec

BNQ is a member of the National
Standards System (NSS).

ANNEX TO THE CERTIFICATE

TECHNOLOGIES BIONEST INC.
(BIONEST TECHNOLOGIES INC.)

55, 12e Rue
Shawinigan, Québec G9T 5K7


NQ 3680-910/2000-06-16 M1 (2004-09-10)

*Wastewater Treatment - Stand-Alone Wastewater Treatment
Systems for Isolated Dwellings*

Page 4 of 5

Certificate number: **900**
Issue date: **2025-10-07**
Expiry date: **2027-10-31**

FLOW DIAGRAM OF BIONEST SYSTEM WITH UV DISINFECTION



THE ANNEX IS AN INTEGRAL PART OF THE CERTIFICATE.



**Bureau de normalisation
du Québec**

BNQ is a member of the National
Standards System (NSS).

ANNEX TO THE CERTIFICATE

TECHNOLOGIES BIONEST INC.
(BIONEST TECHNOLOGIES INC.)

55, 12e Rue
Shawinigan, Québec G9T 5K7

NQ 3680-910/2000-06-16 M1 (2004-09-10)

*Wastewater Treatment - Stand-Alone Wastewater Treatment
Systems for Isolated Dwellings*

Page 5 of 5

Certificate number: **900**
Issue date: **2025-10-07**
Expiry date: **2027-10-31**

HISTORY	
Date	Modification description
2005-10-11	Based on certificate No. 792, certification of models SA-3, SA-4, SA-5 and SA-6, class III and models SA-3D, SA-4D, SA-5D and SA-6D, class V (with UV lamp).
2006-03-17	Issue of certificate No. 900 following a change of address of the manufacturer and the cancellation of certificate No. 792.
2013-10-23	Addition of models SA-6C27, SA-6C32, SA-6C27D and SA-6C32D.
2015-08-17	Removing the nine drawings.
2015-11-02	Renewal of certificate.
2016-05-27	Changing the address of the company.
2017-10-31	Renewal of certificate.Update of the annex.
2018-11-28	Withdrawal of Béton Dunbrick (Div. Gazon Savard Saguenay).
2019-02-06	Withdrawal of G. L'Écuyer transport inc. and Beachburg Ltd., MacGregor Concrete
2019-10-30	Renewal of certificate.
2020-09-30	Precision on a model used and approved as of 2010-01-28: confirmation of UV reactor model Sterilight Cobalt sc320.
2021-10-27	Correction of the hydraulic capacities of the SA-3 model and the definition of the primary treatment in the annex to the certificate. Renewal of certificate..
2021-12-01	Correction of the name of BMR Quincaillerie Touraine for Quincaillerie Touraine.
2023-05-09	Addition of assembler DMA Préfab.
2023-10-19	Renewal of certificate.
2023-02-28	Addition of Aubert et Marois Itée to the plastic system assemblers list. Withdrawal of DMA Préfab and modification of J.M. Turcotte business name for Béton Provincial Itée.
2025-01-10	Name change from Cimenterie Genest to Groupe BPA. Withdrawal of DMA Préfab and Préfab Gosselin
2025-10-07	Renewal of certificate

THE ANNEX IS AN INTEGRAL PART OF THE CERTIFICATE.